



003/24-25

# Report of H2S Analysis of Water

Sample Tested by :	Date of the Sample Collected	No.of Sample Tested	Source & Particulars of Water Sample	Results	
				SPP	NSPP
ಆರ್.ಎನ್.ರಮೇಶ್ ಪ್ರಯೋಗ ಶಾಲಾ ತಂತ್ರಜ್ಞಾಧಿಕಾರಿ ಸ.ಆ.ಕೇ.ಹಾರೋಹಳ್ಳಿ ಕನಕಪುರ (ತಾ),ರಾಮನಗರ (ಜಿ)	17/03/2025		ದಿ ಅರೋಹ ಸ್ಕೂಲ್, ನಂ - 447/173, ವಿಡುಮಡು (ಗಂಟಕನ ದೊಡ್ಡಿ) ಹಾರೋಹಳ್ಳಿ ತಾಲ್ಲೂಕು, ರಾಮನಗರ ಜಿಲ್ಲೆ - 562112. ಇಲ್ಲಿನ ವಿದ್ಯಾರ್ಥಿಗಳಿಗೆ ಕುಡಿಯಲು ಬಳಕೆಗಾಗಿ ನೀರು	✓	NA
NOTE :-					
SPP :- Water is Satisfactory for potable purpose <b>yes</b>					
NSSP :- Water is not Satisfactory for Drinking Purpose					

  
 Dr. Ajit Sabnis  
 Chairman  
 The Auro School

  
 Principal  
 The Auro School  
 Edamadu, Gantakanadoddi  
 Harohalli Taluk,  
 Ramanagara District

For Report  
 ಆಡಳಿತ ವೈದ್ಯಾಧಿಕಾರಿಗಳು  
 ಸಮುದಾಯ ಆರೋಗ್ಯ ಮತ್ತು  
 ಹಾರೋಹಳ್ಳಿ ಕುಟುಂಬ ಕಲ್ಯಾಣ  
 ರಾಮನಗರ ಜಿಲ್ಲೆ.

Translated from the original certificate depicting in Kannada issued by the concerned authority.

003/24-25		Report of H <sub>2</sub> S Analysis of Water			
Sample Tested by:	Date of the Sample Collected	No. of Sample Tested	Source & Particulars of Water Sample	Results	
				SPP	NSPP
R.N. Ramesh Laboratory Technician Govt PHC Harohalli Kanakapura (Tq), Ramanagar (D).	17/03/2025		The Auro School No. 447/173, Edamadu (Gantakanadoddi), Harohalli Taluk, Ramanagara District – 562112.	✓	NA
NOTE:- SPP :- Water is Satisfactory for Potable purpose - Yes. NSSP :- Water is not Satisfactory for Drinking purpose			Students & Staff use of water for drinking purposes.		
Sd/- Lab Technician, Harohalli, Kanakapura Taluk		<p>Dr. Ajit Sabnis Chairman The Auro School</p> <p>Principal The Auro School Edamadu, Gantakanadoddi Harohalli Taluk, Ramanagara District</p>		Sd/- Administrative Health Officer Community Health Care Center Harohalli, Kanakapura Taluk Ramanagara District	



CERTIFIED THAT THIS  
IS A TRUE COPY

MOHAMMED HUSSAIN K, B.A.L.L.B.  
ADVOCATE AND NOTARY  
GOVT OF INDIA  
Reg. No: 20459

No.717, 4th Main Road, COD Lane,  
K.S. Town, Kengeri Upanagara,  
BANGALORE - 560060.

18 MAR 2025





ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಗ್ರಾಮೀಣಾಭಿವೃದ್ಧಿ ಮತ್ತು ಪಂಚಾಯತ್ ರಾಜ್ ಇಲಾಖೆ

ಕಗ್ಗಲಹಳ್ಳಿ ಗ್ರಾಮ ಪಂಚಾಯತಿ ಕಾರ್ಯಾಲಯ

ಹಾರೋಹಳ್ಳಿ ಹೋಬಳಿ, ಕನಕಪುರ ತಾಲ್ಲೂಕು, ರಾಮನಗರ ಜಿಲ್ಲೆ-562 112

ಇ-ಮೇಲ್: kaggalahalligppdo@gmail.com

ಸಂ. ಕಗ್ಗಾಪಂ:65/2023-24

ದಿನಾಂಕ: 06/03/2024

## ದೃಢೀಕರಣ ಪ್ರಮಾಣ ಪತ್ರ

ರಾಮನಗರ ಜಿಲ್ಲೆ, ಹಾರೋಹಳ್ಳಿ ತಾಲ್ಲೂಕು, ಕಗ್ಗಲಹಳ್ಳಿ ಗ್ರಾಮ ಪಂಚಾಯತಿ ವ್ಯಾಪ್ತಿಯ ಗಂಟಕನದೊಡ್ಡಿ (ಎಡುಮಡು ದಾಖಲೆ)ಗ್ರಾಮದ ಗ್ರಾಮ ಪಂಚಾಯತಿ ಸ್ವತ್ತಿನ ಸಂಖ್ಯೆ: 447/173, ಇ-ಸ್ವತ್ತು ಸ್ವತ್ತಿನ ಸಂಖ್ಯೆ: 152900200400420090 ರ ಸ್ವತ್ತಿನಲ್ಲಿ ಶ್ರೀ ಅರಬಿಂದೋ ಕಾಂಪ್ಲೆಕ್ಸ್ ಟ್ರಸ್ಟ್ ರಿ ನ ಪರ ಮ್ಯಾನೇಜಿಂಗ್ ಟ್ರಸ್ಟಿ ಆದ ಅಜಿತ್ ಸಬ್ನಿಸ್ ಬಿನ್ ಎಸ್.ವಿ.ಸಬ್ನಿಸ್ ರವರು ದಿ ಆರೋ ಸ್ಕೂಲ್ ಹೆಸರಿನಲ್ಲಿ ಶಾಲೆ ನಡೆಸಲು ಕಟ್ಟಡ ಸದರಿ ಕಟ್ಟಡ ಕಾಮಗಾರಿ ತಳಮಹಡಿ, ನೆಲಮಹಡಿ, ಮತ್ತು ಮೊದಲನೇ ಮಹಡಿ ಅನುಮೋದಿತ ನಕ್ಷೆಯಂತೆ ಸಂಪೂರ್ಣವಾಗಿ ಕಾಮಗಾರಿ ಮುಗಿದಿರುತ್ತದೆ. ಹಾಗೂ ಶಾಲಾ ಆಡಳಿತ ಮಂಡಳಿಯವರು ಕುಡಿಯುವ ನೀರಿನ ವ್ಯವಸ್ಥೆ, ವಿದ್ಯುತ್‌ಚ್ಚಕ್ತಿ, ಉತ್ತಮ ಸ್ಯಾನಿಟರಿ ಸೌಲಭ್ಯ ವಿಶಾಲವಾದ ತರಗತಿಗಳು ಮತ್ತು ಆಟದ ಮೈದಾನ ಇನ್ನೂ ಮುಂತಾದ ಸೌಲಭ್ಯಗಳನ್ನು ಕಲ್ಪಿಸಿರುತ್ತಾರೆ. ಸದರಿ ಕಟ್ಟಡದಲ್ಲಿ ಶಾಲೆಯನ್ನು ಶೈಕ್ಷಣಿಕ ವರ್ಷ 2024-25ರಿಂದ ಪ್ರಾರಂಭ ಮಾಡಲು ಗ್ರಾಮ ಪಂಚಾಯತಿಯಿಂದ ಯಾವುದೇ ಆಕ್ಷೇಪಣೆ ಇರುವುದಿಲ್ಲ ಎಂದು ಈ ದೃಢೀಕರಣವನ್ನು ಶಾಲೆ ಪ್ರಾರಂಭಕ್ಕೆ ಶಿಕ್ಷಣ ಇಲಾಖೆಯಿಂದ ಅನುಮತಿ ಪಡೆಯಲು ಅನ್ವಯಿಸುವಂತೆ ದೃಢೀಕರಿಸಿ ನೀಡಿದೆ.

ಪಂಚಾಯತಿ ಅಭಿವೃದ್ಧಿ ಅಧಿಕಾರಿ  
ಕಗ್ಗಲಹಳ್ಳಿ ಗ್ರಾಮ ಪಂಚಾಯತಿ  
ಕನಕಪುರ ತಾಲ್ಲೂಕು

ಗೆ,

ಶ್ರೀ ಅಜಿತ್ ಸಬ್ನಿಸ್

ಮ್ಯಾನೇಜಿಂಗ್ ಟ್ರಸ್ಟಿ

ಶ್ರೀ ಅರಬಿಂದೋ ಕಾಂಪ್ಲೆಕ್ಸ್ ಟ್ರಸ್ಟ್,

ಬೆಂಗಳೂರು.

Principal  
The Auro School  
Edamadu, Gantakanadoddi  
Harohalli Taluk,  
Ramanagara District

Dr. Ajit Sabnis  
Chairman  
The Auro School

Translated from the original certificate depicting in Kannada issued by the concerned authority.

Government of Karnataka  
Department of Rural Development and Panchayat Raj  
**Office of Kaggalahalli Gram Panchayat**  
Harohalli Hobli, Kanakapura Taluk, Ramanagar District – 562112

E-mail: kaggahalligppdo@gmail.com

Sl.KGP: 65/2023-24

Date: 06/03/2024

### Confirmation Certificate

Ramanagar District, Harohalli Taluk, Kaggalahalli Gram Panchayat limit, Gantakanadoddi (Edamadu) vide Property Number: 447/173, E-Katha Number: 152900200400420090, the property is owned by the of Sri Aurobindo Complex Trust, promoted and managed school in the name of The Auro School. The work of the said building; the cellar floor, the ground floor, and the first floor are completed as per the approved plan. The School Management has **provided safe drinking water**, electricity, **good sanitary facilities**, spacious classrooms and playground and other required facilities. This letter has been issued to confirm that there is no objection from the Gram Panchayat to start the school in the said building from the Academic Year 2024-25 and to apply for permission from the Education Department for commencement of the school.

Dr. Ajit Sabnis  
Chairman  
The Auro School

Sd/-

Panchayat Development Officer  
Kaggalahalli Gram Panchayat  
Kanakapura Taluk

Principal  
**The Auro School**  
Edamadu, Gantakanadoddi  
Harohalli Taluk,  
Ramanagara District

To  
Sri Ajit Sabnis  
Managing Trustee  
Sri Aurobindo Complex Trust  
Bangalore



CERTIFIED THAT THIS  
IS A TRUE COPY

MOHAMMED HUSSAIN, K, BAL, LLB  
ADVOCATE AND NOTARY  
GOVT OF INDIA  
Reg. No: 20459  
No.717, 4th Main Road, COD Lane,  
K.S. Town, Kengeri Upanagara,  
BANGALORE - 560060.

18 MAR 2025



Report Details:

PL/FOR/QA/018/01

ULR Number	TC133522500000848F		
Amended Report Date	Not Applicable	Original Report Date	18 March 2025
Sample Number	PL/W/24-25/04108	Sample Receipt Date	14 March 2025
Customer Details	The Auro School #447/173, Yadamadu Village, Gantakana Doddi, Harohalli Hobli, Kanakapura Road, Ramanagara District, Karnataka		
Customer Contact Number	9741360635	Customer Mail ID	sactmsf@gmail.com
Analysis Start Date	14 March 2025	Analysis End Date	18 March 2025

Sampling Details:

Sample Name	Filtered Drinking Water	Sample Group/Matrix	Drinking Water
Sampling Location (If Any)	Not Applicable		
Sample Drawn By	Customer	Sample Quantity Drawn	1000mL
Batch Number (If Any)	Not Applicable	Sample Package (If Any)	PP Bottle
Sampling Method	Not Applicable	Sample Conditions	Good

Testing Environmental Conditions:

Temperature	20°C - 25°C	Humidity	45% - 75%
-------------	-------------	----------	-----------

Test Results:

Sl. No.	Test Parameters (UOM)	Test Method	Test Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Colour	IS : 3025 (part 4)	<1	Maximum 5 Hazens
2	Odour	IS : 3025 (part 5)	Agreeable	Agreeable
3	Turbidity	IS : 3025 (part 10)	<0.5	Maximum 1 NTU
4	pH	IS : 3025 (part 11)	7.1	6.5 – 8.5
5	Total Dissolved Solids	IS : 3025 (part 16)	317	Maximum 500 mg/L
6	Total Hardness as CaCO <sub>3</sub>	IS : 3025 (part 21)	152	Maximum 200 mg/L
7	Calcium as Ca	IS : 3025 (part 40)	44.9	Maximum 75 mg/L
8	Magnesium as Mg	IS : 3025 (part 46)	10.3	Maximum 30 mg/L
9	Chloride as Cl	IS : 3025 (part 32)	42	Maximum 250 mg/L
10	Total Alkalinity as CaCO <sub>3</sub>	IS : 3025 (part 23)	165	Maximum 200 mg/L
11	Sulphates as SO <sub>4</sub>	IS : 3025 (part 24)	17.5	Maximum 200 mg/L
12	Fluoride as F	IS : 3025 (part 60)	0.1	Maximum 1 mg/L
13	Iron as Fe	IS : 3025 (part 53)	<0.075	Maximum 1 mg/L
14	Nitrate as NO <sub>3</sub>	APHA Method-4500	7.8	Maximum 45 mg/L
15	Aluminium as Al	IS : 3025 (part 55)	<0.002	Maximum 0.03 mg/L

Authorized Signatory  
Kumar Swamy M V  
Microbiology

*(Signature)*  
Dr. Ajit Sabnis  
Chairman  
The Auro School

*(Signature)*  
Sahana V Shirali  
Authorized Signatory  
Sahana V Shirali  
Chemistry







## Test Report

PL/FOR/QA/018/01

### Report Details:

ULR Number	Not Applicable		
Amended Report Date	Not Applicable	Original Report Date	18 March 2025
Sample Number	PL/W/24-25/04108	Sample Receipt Date	14 March 2025
Customer Details	The Auro School #447/173, Yadamadu Village, Gantakana Doddi, Harohalli Hobli, Kanakapura Road, Ramanagara District, Karnataka		
Customer Contact Number	9741360635	Customer Mail ID	sactmsf@gmail.com
Analysis Start Date	14 March 2025	Analysis End Date	18 March 2025

### Sampling Details:

Sample Name	Filtered Drinking Water	Sample Group/Matrix	Drinking Water
Sampling Location (If Any)	Not Applicable		
Sample Drawn By	Customer	Sample Quantity Drawn	1000mL
Batch Number (If Any)	Not Applicable	Sample Package (If Any)	PP Bottle
Sampling Method	Not Applicable	Sample Conditions	Good

### Testing Environmental Conditions:

Temperature	20°C - 25°C	Humidity	45% - 75%
-------------	-------------	----------	-----------

### Test Results:

Sl. No.	Test Parameters (UOM)	Test Method	Test Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Zinc as Zn	IS : 3025 (part 49)	<0.1	Maximum 5 mg/L
2	Boron as B	IS : 3025 (part 57)	<0.1	Maximum 0.5 mg/L


**Statement of Conformity:** The given sample conforms to IS 10500:2012 Drinking water specification (Acceptable limit) for the above tested parameters.

### Note:

1. The reported findings are specific to the tested sample and relevant parameters.
2. In the event of a dispute, our liability is capped at the total invoiced amount received by us.
3. Upon request, samples will be stored for 15 days. Perishable samples will be promptly discarded immediately after analysis.
4. This report may not be reproduced in part without the laboratory's approval and is not admissible as evidence in legal proceedings.
5. The copyright for the Test Report, its information, and data (excluding customer-provided information) belongs to Prewel Labs Pvt. Ltd. and must not be replicated in any form.
6. Any proprietary knowledge developed by Prewel Labs Pvt. Ltd. during the assigned work remains the sole property of Prewel Labs Pvt. Ltd. The customer/client may not use or disclose this information without express written permission.
7. Any discrepancies in the Test Report must be reported to Prewel Labs Pvt. Ltd. within 30 days of a report being released.

### End of the Report

Dr. Ajit Sabnis  
Chairman  
The Auro School



**Prewel Labs Pvt. Ltd.**



+91-63669 42390



CIN : U85300KA2021PTC147708

www.prewellabs.com



#24, 22nd Main Road, Marenahalli, J.P. Nagar 2nd Phase, Bengaluru - 560 078



support@prewellabs.com





<b>ULR Number</b>	TC8828230000001144F		
<b>Sample Number</b>	PL/W/23-24/1296	<b>Report Date</b>	14 December 2023
<b>Customer details</b>	The Auro School #447/173, Yadamadu Village, Gantakana Doddi, Harohalli Hobli, Kanakapura Road, Ramanagara District, Karnataka		
<b>Sample Details</b>	Drinking Water (Filtered Water)		
<b>Sample Condition</b>	Good	<b>Sample Received date</b>	06 December 2023
<b>Sample Package</b>	NA	<b>Analysis Started on</b>	07 December 2023
<b>Sample provided by</b>	Customer	<b>Analysis Ended on</b>	14 December 2023

Sl. No.	Parameters	Test method	Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Odour	IS : 3025 (part 5)	Agreeable	Agreeable
2	Turbidity	IS : 3025 (part 10)	<0.5	Maximum 1 NTU
3	pH Value	IS : 3025 (part 11)	7.2	6.5 – 8.5
4	Total Dissolved Solids	IS : 3025 (part 16)	370	Maximum 500 mg/L
5	Total Hardness as CaCO <sub>3</sub>	IS : 3025 (part 21)	132	Maximum 200 mg/L
6	Calcium as Ca	IS : 3025 (part 40)	37	Maximum 75 mg/L
7	Magnesium as Mg	IS : 3025 (part 46)	10	Maximum 30 mg/L
8	Chloride as Cl	IS : 3025 (part 32)	76	Maximum 250 mg/L
9	Total Alkalinity as CaCO <sub>3</sub>	IS : 3025 (part 23)	135	Maximum 200 mg/L
10	Sulphates as SO <sub>4</sub>	IS : 3025 (part 24)	15	Maximum 200 mg/L
11	Fluoride as F	IS : 3025 (part 60)	0.1	Maximum 1 mg/L
12	Iron as Fe	IS : 3025 (part 53)	<0.1	Maximum 1 mg/L
13	Total Coliform Bacteria	IS : 15185 : 2016	Absent	Shall not be detectable in 100 mL sample
14	<i>E.Coli</i>	IS : 15185 : 2016	Absent	

**Inference:** The given sample conforms to IS 10500:2012 Drinking water specification (Acceptable limit) for the above tested parameters.

**Note:**

1. The results listed refer only to the tested sample and applicable parameters.
2. In case of dispute our liability is limited to the billed amount received by us.
3. Samples will be preserved for 15 days on request. Food samples and microbiology samples will be discarded after analysis.
4. This certificate shall not be reproduced except full without approval of the laboratory and cannot be used as evidence in the court of law.

**Authorized Signatory**

Ambarish M Ghali  
Director - Prewel Labs  
Microbiology



*Dr. Ajit Saknis*

Dr. Ajit Saknis  
Chairman  
Page No. 01 of 01

**Authorized Signatory**

Mahadeva M J  
Assistant Manager Prewel Labs  
Chemistry





**TEST REPORT**

PL/FOR/016/01

<b>Sample Number</b>	PL/W/23-24/1296	<b>Report Date</b>	14 December 2023
<b>Customer details</b>	The Auro School #447/173, Yadamadu Village, Gantakana Doddi, Harohalli Hobli, Kanakapura Road, Ramanagara District, Karnataka		
<b>Sample Details</b>	Drinking Water (Filtered Water)		
<b>Sample Condition</b>	Good	<b>Sample Received date</b>	06 December 2023
<b>Sample Package</b>	NA	<b>Analysis Started on</b>	07 December 2023
<b>Sample provided by</b>	Customer	<b>Analysis Ended on</b>	14 December 2023

Sl. No.	Parameters	Test method	Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Colour	IS : 3025 (part 4)	<5	Maximum 5 Hazens
2	Nitrate as NO <sub>3</sub>	APHA Method-4500	5	Maximum 45 mg/L
3	Zinc as Zn	IS : 3025 (part 49)	<0.1	Maximum 5 mg/L
4	Aluminium as Al	IS : 3025 (part 55)	<0.02	Maximum 0.03 mg/L
5	Boron as B	IS : 3025 (part 57)	<0.1	Maximum 0.5 mg/L

**Inference:** The given sample conforms to IS 10500:2012 Drinking water specification (Acceptable limit) for the above tested parameters.

**Note:**

1. The results listed refer only to the tested sample and applicable parameters.
2. In case of dispute our liability is limited to the billed amount received by us.
3. Samples will be preserved for 15 days on request. Food samples and microbiology samples will be discarded after analysis.
4. This certificate shall not be reproduced except full without approval of the laboratory and cannot be used as evidence in the court of law.

**Authorized Signatory**

Mahadeva M J  
Assistant Manager - Prewel Labs  
Chemistry



**End of the Report**



Dr. Ajit Sabnis  
Page No. 01 of 01  
The Auro School

